



ELEVATION NOTES

1. THIS DRAWING IS FOR DIAGRAMMATIC PURPOSES ONLY. FOR ACTUAL HANDING AND SWING, REFERENCE FLOOR PLANS.
2. DIMENSIONS SHOWN FOR COORDINATION ONLY. EXACT LOCATIONS AND MOUNTING HEIGHTS TO BE FIELD COORDINATED WITH OWNER AND ARCHITECT.
- 3 IF PLENUM INSTALLATION, CONDUIT IS NOT REQUIRED FOR THIS CABLE RUN.
- 4 IF PLENUM INSTALLATION, STUB CONDUIT, w/PULL STRING, 6" ABOVE FINISHED CEILING.
5. ALL CONDUIT IS 3/4" UNLESS OTHERWISE NOTED.
- 6 FOR GROUTED DOOR FRAMES, PROVIDE CONDUIT INTO SPECIAL STEEL BOX OR STYROFOAM BLOCK TO FACILITATE BOTH INSTALLATION AND SERVICE.
8. FIELD VERIFY ALL EXISTING INSTALLATION.
9. ALL NEWLY INSTALLED ITEMS SHALL BE INSPECTED BY UNIVERSITY INSPECTOR.

HB-5

DOUBLE DOOR, ALARMED/FREE EXIT
ELECTRIC LOCKSET w/REX SWITCH, LOCAL NOISE (SIREN & PIEZO)
ELEVATION

SCALE: N.T.S.

LBNL ELECTRICAL STANDARDS
SECURITY CARD ACCESS HB-5
DOUBLE DOOR, ALARMED/FREE EXIT, MANUAL LOCKSET

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE	N.T.S.
DRAWING NO.	SHEET
SEC108A	HB-5
PROJECT NO.	